

**Finance**

Purchasing Division
305 Chestnut Street, 5th Floor
Post Office Box 1810
Wilmington, NC 28402-1810

910 341-7830
910 341-7842 fax
wilmingtonnc.gov
Dial 711 TTY/Voice

ADDENDUM NUMBER 2
17th Street Streetscape Improvements
PAV-IH-0316
February 24, 2016

To all holders of Bid Documents; please be advised to the following:

THIS ADDENDUM DOES NOT CHANGE THE BID OPENING DATE

Answers to plan questions:

1. In regard to line item 56, Simulated Brick Crosswalk, on sheet 6 there is a call out for StreetPrint HD Crosswalk See Detail (Typ). I do not see a detail for this work. Please clarify.

The Typical Crosswalk Detail is on page 15 which includes the StreetPrint HD details. Installation is to be in accordance with the manufacturer's specifications.

2. In regard to line item 124, Park Benches, per detail, complete-in-place. I do not see a detail, please clarify.

The park bench detail was not included in the plans. The detail is provided as Attachment 1 of this addendum.

3. The details on sheet 15 show 6" of ABC under the curbs and gutters, sidewalks, driveways, etc. How is this material to be paid?

All stone base will be paid under Item #9, Incidental Stone Base, 6".

4. Item 22 calls for 2' Vertical Curb. There are two details on sheet 15 for vertical curb, one that illustrates 18" tall curb and another that appears to be 16". Please clarify the correct detail to be used.

Use 18" vertical curb detail for all vertical curb.

5. The details on sheet 15 call out concrete to be 3000 PSI Min for curb and gutter, sidewalks, and driveways. The line items reference NCDOT standard numbers which call for Class B concrete (2500 PSI). Please clarify the concrete requirement.

Use DOT specification, 2,500 psi minimum.

Answers to irrigation questions:

1. $\frac{3}{4}$ quick coupler valve with a 1" swing joint. Can we use $\frac{3}{4}$ swing joint or a 1" quick coupler valve so they fit together?

A $\frac{3}{4}$ " swing joint with $\frac{3}{4}$ " coupler or 1" swing joint with 1" coupler can be used.

2. Do they truly want a pressure regulating head for the sprays?

A pressure regulating head is required.

3. They call out a Node for a controller. The Node is an in-ground battery operated controller. They also call out a wall mounted or pedestal controller. The wall mounted is a XCH. They cannot get that in a pedestal. XCH can be mounted on a stainless steel pole if that will meet the spec.

A Node controller is required. A wall mounted or pedestal controller is not required.

4. They are calling out a Johnson temperature control sensor. Will a RainBird or Hunter rain/freeze sensor meet the requirement?

A Hunter rain/freeze sensor will meet the requirement.

All other terms and conditions remain unchanged. Acknowledge receipt of this Addendum in the space provided in the Proposal. Failure to do so may disqualify the Bidder.

Daryle L. Parker, Purchasing Manager
Purchasing Division
END OF ADDENDUM TWO

Attachment 1
Park Bench Detail

PARK BENCH

